



Health
Canada

Healthy Environments
and Consumer Safety
Branch

Santé
Canada

Direction générale,
Santé environnementale et
sécurité des consommateurs

Your file *Votre référence*

Our file *Notre référence*

Safe Environments Directorate
Water Quality and Microbiology Division
A.L. 3505A
123 Slater Street
Ottawa, Ontario
K1A 0K9

December 12, 2001

Mr. Ron Hallett, P.Eng.
President
UV Pure Technologies Inc.
60 Venture Drive, Unit 19
Scarborough, ON
M1B 3S4

**Subject: Request for a Letter of No-Objection for the Hallett Water Unit 10
Ultraviolet Light Drinking Water Treatment Unit**

Dear Mr. Hallett,

I am writing with reference to your request of November 29, 2001, for a letter of no objection regarding the Hallett Water Unit 10 Ultraviolet Light Drinking Water Treatment Unit (DWTU).

At the present time, no regulations are in place under the authority of Health Canada for drinking water materials. To promote public health and safety, Health Canada strongly recommends that products that come into contact with drinking water be certified as meeting the appropriate ANSI/NSF Standard—in this instance, ANSI/NSF Standard 55 Class A.

Provided the above-mentioned product is, and continue to be, certified as meeting NSF Standard 55 Class A, Health Canada has no objection to its use in drinking water systems, in accordance with the requirements indicated in the certification.

.../2

Canada